

# TABB Instruments List

## Minimum Instruments required for TABB Certified Contractor

1 Function	2 Range	3 Minimum Accuracy	4 Required Calibration	5 Specific Information	6 Calibration Maintained
Temperature Measuring	25°F - 180° F	±1° F from 25° - 180° F	24 months	Mfr:  Model  Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/>  Last Calibration Date: _____
Electrical Measuring Instruments	0 - 600 volts  0 -100 amps  0 – 30 VDC	3% of Full Scale	Digital - 12 months  Analog - 6 months	Mfr:  Model  Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/>  Last Calibration Date: _____
Rotation Measuring Instrument	0 to 3000 RPM	± 1% of reading	24 months	Mfr:  Model  Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/>  Last Calibration Date: _____
Air Pressure Measuring Instrument Static and Differential	1.25 Pa to 4,500 Pa with conversion to inches of water.	± 3% of reading	24 months	Mfr:  Model  Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/>  Last Calibration Date: _____
Air Velocity Measuring Instrument	Minimum Range: 100 to 3000 FPM	± 4% of reading	24 months	Mfr:  Model  Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/>  Last Calibration Date: _____

1 Function	2 Range	3 Minimum Accuracy	4 Required Calibration	5 Specific Information	6 Calibration Maintained
Air Volume Measuring Instrument	Minimum Range: 20 CFM to 2,500 CFM	± 3% of reading	24 months	Mfr: Model Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/> Last Calibration Date: _____
Humidity Measuring Instrument	10% - 90% rh	2% RH Range: 10-90% RH	24 months  No calibration required for analog thermometer type of psychrometer	Mfr: Model Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/> Last Calibration Date: _____
Hydronic Pressure Measuring Instrument Static and Differential	0 – 150 PSI	± 3% of reading	24 months	Mfr: Model Range of this Instrument:	Y <input type="checkbox"/> N <input type="checkbox"/> Last Calibration Date: _____